

**RAINWATER HARVESTING OPERATION AND MAINTENANCE
AGREEMENT**

Project Name: _____

Project Location: _____

SCM as Identified on Approved Plans: _____

PIN Number: _____

Mail after recording to: City of Burlington
Water Resources
P.O. Box 1358
Burlington, NC 27216

NORTH CAROLINA

ALAMANCE COUNTY

This STORMWATER OPERATION AND MAINTENANCE AGREEMENT,

made this day _____ of _____, 20 _____ by

_____ whose principal address is

_____ with, to, and for the

benefit of the City of Burlington, a municipal corporation of the State of North Carolina, whose address is P.O. Box 1358, Burlington, North Carolina 27216.

Rainwater Harvesting System Operation and Maintenance Agreement

I will keep a maintenance record on this Stormwater Control Measure (SCM). This maintenance record will be kept in a log in a known set location. Any deficient SCM elements noted in the inspection will be corrected, repaired or replaced immediately. These deficiencies can affect the integrity of structures, safety of the public, and the removal efficiency of the SCM.

Important maintenance procedures:

- The roof area will be maintained to reduce the debris and sediment load to the system. Excess debris can clog the system and lead to bypass of the design storm, and reduced reuse volume.
- To ensure proper operation as designed, a licensed Professional Engineer, Landscape Architect, or other qualified professional will inspect the system annually.
- The system components will be repaired or replaced whenever they fail to function properly.
- If the outlet is metered, use must be recorded at a minimum of monthly. These records shall be kept on site for inspection by DWQ.

The system will be inspected by the owner/operator at least **monthly and within 24 hours after each rain event**. Records of operation and maintenance will be kept in a known set location and will be available upon request. **Annually, by May 31, an inspection shall be completed by a qualified professional and submitted to the City of Burlington.**

Inspection activities shall be performed as follows. Any problems that are found shall be repaired immediately.

SCM element:	Potential problems:	How to remediate the problem:
The entire system	A component of the system is damaged or leaking.	Make any necessary repairs or replace if damage is too large for repair.
	Water is flowing out of the overflow pipe during a design rainfall or smaller (usually a 1” or 1.5” rainfall).	Check system for clogging and damage. Repair as needed so the design volume is stored properly without discharging during a design storm. Check that the pump is operating properly and that the water is actually being used at the volume designed. If it is still not operating properly, then consult an expert.
The captured roof area	Excess debris or sediment is present on the rooftop.	Remove the debris or sediment as soon as possible.
The gutter system	Gutters are clogged, or water is backing up out of the gutter system.	Unclog and remove debris. May need to install gutter screens to prevent future clogging.
	Rooftop runoff not making it into gutter system.	Correct the positioning or installation of gutters. Replace if necessary to capture the roof runoff.

SCM element:	Potential problems:	How to remediate the problem:
The pump	Pump is not operating properly.	Check to see if the system is clogged and flush if necessary. If it is still not operating, then consult an expert.
The overflow pipe	Erosion is evident at the overflow discharge point.	Stabilize immediately.
	The overflow pipe is clogged.	Unclog or replace if it cannot be unclogged.
	The outflow pipe is damaged.	Repair or replace the pipe.
The secondary water supply	Not operating properly.	Consult an expert.
The cistern	Sediment accumulation of 5% or more of the design volume.	Remove sediment.
	Algae growth is present inside the cistern.	Do not allow sunlight to penetrate the cistern. Treat the water to remove/prevent algae.
	Mosquitoes in the cistern.	Check screens for damage and repair/replace. Treat with 'mosquito dunks' if necessary.
The screens and filters	Debris and/or sediment has accumulated. Screens and filters are clogged.	Search for the source of the debris/sediment and remedy the problem if possible. Clean/clear debris/sediment from screen or filter. Replace if it cannot be cleaned.

I acknowledge and agree by my signature below that I am responsible for the performance of the maintenance procedures listed above. I agree to notify the City of Burlington of any problems with the system or prior to any changes to the system or responsible party.

This Agreement shall be binding upon the undersigned and its successors and assigns and all current and future owners thereof, and their respective heirs, successors and assigns, in perpetuity, and shall be appurtenant to, run with, and burden the parcels of land referred to herein.

Project name: _____

SCM as Identified on Approved Plans: _____

Print name: _____

Title: _____


Address: _____

Phone: _____

Signature: _____

Date: _____

I, _____, a Notary Public for the State of _____, County of _____, do hereby certify that _____ personally appeared before me this _____ day of _____, _____, and acknowledge the due execution of the forgoing rainwater harvesting maintenance requirements. Witness my hand and official seal,



SEAL

My commission expires _____